


Missouri Department of Transportation  
Kevin Keith, Director

573.751.2551  
Fax: 573.751.6555  
1.888.ASK MODOT (275.6636)

**ADDENDUM 001  
REQUEST FOR BID  
Macks Creek Radio Tower  
Request for Bid 9-120905RJ**

Bidders should acknowledge receipt of Addendum 001 (ONE) by **signing** and **including it** with the original bid. The due date for receipt of proposals remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Reva Jones Senior General Services Specialist
Contractor/Offeror Signature	Department of Transportation 
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: August 21, 2012

The following information has been revised and/or clarified by addendum #001:

The first statement under the General Section of the Specifications for Furnishing and Erecting Steel Radio Tower Macks Creek, Missouri has been revised as follows:

***In the event of a conflict, the specifications for furnishing and erecting steel radio tower Macks Creek, Missouri will prevail over Sections 00100 – 03370 in the RFB document.***



*Our mission is to provide a world-class transportation experience that delights our customers and promotes a prosperous Missouri.*

www.modot.org

**Question:** The specification shows the new tower to be designed in accordance with the TIA-222-G standard but does not identify the structure classification. Will this tower be a Class 2 or Class 3?

**Answer:** The Macks Creek Tower shall be designed as a Class 2 tower with the loadings specified in the bid document.

### **Section 01019 (Page 16)**

#### CONTRACT REQUIREMENTS

##### 1.2 SCHEDULE OF VALUES

- B. Submit Schedule of Values in duplicate within *5 days* after date of Owner-Contractor Agreement.

### **Section 01650 (Page 32)**

#### STARTING OF SYSTEMS REQUIREMENT

##### 1.4 DEMONSTRATION AND INSTRUCTIONS

- A. Demonstrate operation and maintenance of Products to Owner's personnel *one (1)* week prior to date of Final Completion.

### **Section 02050 (Page 38)**

#### DEMOLITION

3.3 J has been deleted by addendum #001.

### **Section 02830 (Page 40)**

#### CHAIN LINK FENCES

##### 1.2 SUBMITTALS

- A. Product data: Within *5* calendar days after the Contractor has received the Owner's Notice to Proceed, submit:

**Section 02830 (Page 42)**

CHAIN LINK FENCES

2.5 GATES

C. Gates:

1. Swing Gates: Swing gates shall comply with the requirements of ASTM F 900. Provide the following for *each* 3' gate: