


Missouri Department of Transportation
Kevin Keith, Director

573.751.2551
Fax: 573.751.6555
1.888.ASK MODOT (275.6636)

**ADDENDUM 002
REQUEST FOR BID
Central Office Lab Reroof
Request for Bid 9-120918RJ**

Bidders should acknowledge receipt of Addendum 002 (TWO) by **signing** and **including** it with the original bid. The due date for receipt of proposals remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Reva Jones Senior General Services Specialist
Contractor/Offeror Signature _____	Department of Transportation  _____
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: September 10, 2012

The following paragraphs in Section 01500 (Page 28) have been deleted by addendum #002:

- 1.2 TEMPORARY ELECTRICITY
- 1.3 TELEPHONE SERVICE
- 1.4 FACSIMILE SERVICE



Our mission is to provide a world-class transportation experience that delights our customers and promotes a prosperous Missouri.

www.modot.org

The following information is clarified by addendum #002:

In lieu of the 3" tapered insulation the Contractor is to install 3" flat polyiso R-18.5 insulation and cricket to roof drains as required.

The roof shall be sealed weather tight at the end of each work day.

Pavers shall be stacked on the ground at the project site. Balast will be stock-piled a quarter mile from the project site on MODOT property.

Surface mounted PVC condensation pipe will be removed by MoDOT.