

Missouri
Department
of Transportation




Kevin Keith, Director

105 West Capitol Avenue
P.O. Box 270
Jefferson City, MO 65102
(573) 751-2551
Fax (573) 751-6555
www.modot.org

**ADDENDUM 001
REQUEST FOR BIDS
Wayland Truck Wash (RFB 9-120628TV)**

Bidders should acknowledge receipt of Addendum 001 (ONE) by **signing and including it** with the original bid. The due date for receipt of proposals remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Name: Tom Veasman Title: Sr. General Services Specialist
Contractor/Offeror Signature	Department of Transportation 
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: 6/25/12

CHANGE TO SITE NOTE #1 ON PAGE 2 OF THE WAYLAND DRAWINGS:

CONTRACTOR TO REMOVE EXISTING 6" EXTERIOR CONCRETE WASH SLAB AND 4' FOUNDATION WALL WITH 2' WIDE FOOTINGS (EAST AND SOUTH SIDES) WHERE NEW BUILDING IS TO BE BUILT. DISCARD CONCRETE/REBAR DEBRIS AT THE WAYLAND MAINTENANCE FACILITY AS DIRECTED BY THE FACILITIES OPERATIONS SUPERVISOR. REINSTALL 360' WASH BOOK AND WALL MOUNTED BRUSH AND WALL BRACKET IN NEW BUILDING FOR FUNCTIONAL SERVICE. RETURN VERTICAL POST TO OWNER.

ADDITION TO SPECIFICATIONS:

Section 07600 FLASHING AND SHEET METAL, Sub-section 2.3 METAL ROOF FLASHING & TRIM on Page 97 should include the following additional language:

- C. All exposed steel trim or steel flashing surfaces should be painted with Kynar 500 paint.

CHANGE TO SPECIFICATIONS:

Specifications Section 16108, Sub-Section A(Page 141) has been changed to read as follows:

16108 CONDUIT

- A. All interior wiring above grade that may be exposed to moisture shall be installed in Schedule 40 PVC pipe. All interior wiring above grade that will not be exposed to moisture shall be installed in electrical metallic tubing with screw coupling fittings.

CHANGE TO SPECIFICATIONS:

Section 08300 FIBERGLASS REINFORCED PLASTIC DOORS AND FRAMES (Pages 111 & 112) of the Wayland Truck Wash Specifications should be replaced with the following:

R51SS - All Stainless Steel Prehung Walk Door

A.J. Manufacturing, Inc.
1217 Oak Street
Bloomer, WI 54724
Phone: 800-328-9448 or 715-568-2204
Fax: 715-568-3099
www.ajdoor.com

R51SS is a Prehung, 2-way, insulated stainless steel cake pan panel with stainless steel jambs, head, sill, window frame, hinges, and fasteners.

DOOR HARDWARE:

- Door is mounted to the frame by the three, 12 gauge, 4-1/2" x 4" fixed pin stainless steel hinges.
- Door is prepped for lockset by boring a 2-1/8" diameter hole with a 2-3/4" backset and a 1" edge bore.
- Door panel is strengthened with a steel C channel at the location for entry lock.
- All fasteners are stainless steel.

DOOR LITE:

22" x 22" Insulated Vue Lite, consisting of 2 pieces of 1/8" tempered glass with 1/2" dead air space.